


NOTES:

1. FOUNDATION, BEDDING AND HAUNCHING SHALL BE #57 STONE.
2. INITIAL BACKFILL FOR GRAVITY SEWER SHALL BE CLASS II OR BETTER SELECT COMMON FILL.
3. INITIAL BACKFILL FOR SANITARY FORCEMAIN SHALL BE CLASS III OR BETTER SELECT COMMON FILL.
4. FINAL BACKFILL SHALL BE CLASS III OR BETTER COMMON FILL.
5. SEE CITY OF SAVANNAH STANDARD SPECIFICATIONS SECTION 02554 PART 2.11 FOR MORE DETAILS.

STANDARD PIPE BEDDING DETAIL

STANDARD
CONSTRUCTION
DETAILS



CITY OF
savannah

WATER RESOURCES AND PUBLIC WORKS BUREAU
Planning & Engineering

SCALE: N.T.S.

DATED: MAR 2014

PLATE NUMBER:

S16